



VS299/VOICE SIREN DRIVER

INSTALLATION INSTRUCTIONS

Features

- Generates voice output in English, French, and Spanish.
- Separate messages for FIRE and BURGLARY conditions.
- Separate siren sounds for FIRE and BURGLARY conditions.
- Terminal strip for secure connection to control panel.
- Selectable input level (High/Low) for FIRE/BURGLARY inputs.
- Supervision feature for speaker and speaker wiring.
- Compatible with most control panels.
- Sounder options for bell ringback/bell test.
- Compatible with 8-16-ohm speakers.
- Operates on 12-16V DC.
- Small compact size for easy installation using double-sided tape (packed separately) - measures only 4" x 2-5/8" x 1-1/4".

Output Selection

The voice driver can be programmed for the desired alarm output on burglary and fire by means of jumpers JP1 through JP4, as indicated in Table 1. See Figure 1 for location of jumpers.

Table 1. Output Selection

JUMPERS				OUTPUT	
JP1	JP2	JP3	JP4	FIRE	BURG
—	—	—	—	ENG	ENG
X	—	—	—	ENG/FREN	ENG/FREN
—	X	—	—	ENG/SPAN	ENG/SPAN
X	X	—	—	ENG/SPAN/FREN	ENG/SPAN/FREN
—	—	X	—	FREN	FREN
X	—	X	—	SPAN	SPAN
—	X	X	—	SIREN	SIREN
X	X	X	—	ENG	SIREN
—	—	—	X	ENG/FREN	SIREN
—	—	X	X	ENG/SPAN	SIREN
—	X	—	X	ENG/SPAN/FREN	SIREN
—	X	X	X	SIREN	ENG
X	—	X	X	SIREN	FREN
X	X	—	X	SIREN	SPAN
X	—	—	X	SIREN	ENG/SPAN/FREN
X	X	X	X	ENG	ENG

X = CUT, — = INTACT

Bell Test/Ringback Options (JP5)

If jumper JP5 is kept intact, the siren driver will generate a steady sound for bell test and bell ringback conditions. If the jumper is cut, a warbled sound will be generated for bell test/ringback conditions.

Note: If this mode is selected, a fire signal will momentarily generate a warbled siren sound for the initial portion of the siren sound and then revert to the normal siren sound and voice message.

Burglary Signal Polarity (JP6)

Intact = High (12V+), cut = Low (0V).

The burglary message may be activated by either a steady logic high or a steady logic low, as provided by the control panel (refer to the control panel's instructions).

When jumper JP6 is intact, activation is by a logic high (12V+) at terminal 2. Cut jumper JP6 for activation by a logic low (0V). Note that a pulsing high or low (pulse width 0.25 to 1.75 seconds, that is provided by some panels) connected to the Burglary/Fire input (terminal 2) will be interpreted as a Fire condition and will produce the fire message.

Fire Signal Polarity (JP7)

Intact = High (12V+), cut = Low (0V).

As in the case of Burglary signal polarity, the fire message may be activated by either a logic high or logic low, but at terminal 3. When jumper JP7 is intact, activation is by a logic high (12V+). Cut jumper JP7 for activation by a logic low (0V). Do not pulse the input to terminal 3.

Burglary Messages:

ENGLISH:

YOU HAVE VIOLATED A PROTECTED AREA . . . THE POLICE HAVE BEEN CALLED . . . LEAVE IMMEDIATELY!

SPANISH:

USTED/HA VIOLADO UNA AREA PROTEVIDA . . . LA POLICIA HA SIDO LLAMADA . . . SALGA INMEDIATAMENTE!

FRENCH:

VOUS AVEZ PENETRE UN LIEU SURVEILLE . . . LA POLICE A ETE AVERTI . . . EVAQUEZ IMMEDIATEMENT!

Burglary Alarm Sequence:

Warble Siren sound, Burglary Voice Message (repeated 3 times), 15-second Warble Siren Sound. Sequence will repeat until the Burglary output condition is terminated.

Fire Messages:

ENGLISH: FIRE . . . LEAVE IMMEDIATELY!

SPANISH: FUEGO . . . SALGA INMEDIATAMENTE!

FRENCH: AU FEU! . . . EVAQUEZ IMMEDIATEMENT!

Fire Alarm Sequence:

Steady Siren Sound, Fire Voice Message repeated 3 times on single language output, followed by 15 seconds of Steady Siren Sound. Sequence will repeat until the Fire output condition is terminated.

Wiring Connections

Wiring connections to the terminals are as follows. Refer to Figure 1 (and Table 2 for FBI products).

1 SUPV: SPEAKER/WIRING SUPERVISION (OPTIONAL)

For supervision of speaker and associated wiring, connect to a 24-hour zone that is activated by a short. Removing the speaker or shorting either speaker terminal to ground will appear as a short on the zone. Note that in series-connected multiple speaker systems, cutting any speaker will trip the control panel's supervision zone. In parallel-connected speaker systems, each branch must be cut before the control panel's supervision zone will trip.

2 B/F: BURGLARY/FIRE INPUT:

Connect the control panel's Burglary (steady) Output to this terminal. This terminal may also be used to trip the FIRE message if the control provides a pulsing output for fire (re-programming may be required). In this case, no connection to terminal 3 is required.

3 F: FIRE INPUT:

Connect the control panel's output designated as the FIRE (steady) Output to this terminal (unless this output was connected to terminal 2).

4 SPKR & 5 SPKR: SPEAKER TERMINALS:

Connect an 8-ohm or 16-ohm 15-watt speaker to these terminals. See Figure 3 for multiple speaker configurations.

6 (+): 12VDC(+) POWER INPUT:

Connect to a 12VDC (+) source on the control; since the driver can draw as much as 1.1 amps, it may be necessary in some cases (see Table 2 for FBI products) to connect to the system's back-up battery through a 2 amp in-line fuse, as shown in Figure 2.

7 (-): 12VDC(-) POWER INPUT:

Connect to a ground point (-) on the control panel.

Speakers: Use 15-watt speakers.

Sound Output: 108dB @ 10 ft.

Current Drain (at 12V DC):

8-ohm Speaker: 1100 mA (steady siren)

12-ohm Speaker: 950 mA (steady siren)

16-ohm Speaker: 800 mA (steady siren)

1400 mA
1050 mA
875 mA

Important: We recommend that the VS299 be mounted in the control cabinet, not remotely.