



NAPCO SECURITY GROUP, INC.

333 Bayview Avenue, Amityville, New York, U.S.A. 11701
800-645-9445 (631) 842-9400 FAX (631) 842-9137

FIREWOLF FW-2 SMOKE DETECTOR PRODUCT ADVISORY

Date: June 11, 2001

To: All NAPCO Distributors and Dealers

Subject: Silent Knight 5204 Fire Alarm Control Panel and NAPCO Firewolf FW-2 Smoke Detector.

Although the Silent Knight 5204 and NAPCO FW-2 are cross listed by Underwriters Laboratories as compatible, it has come to our attention during a recent investigation that the Silent Knight 5204 FACP is not able to sustain an alarm condition from the FW-2 smoke detector. Fortunately, the inability of the 5204 / FW-2 combination to function properly will be evidenced upon initial inspection of the system when installed and tested.

Please be aware that this advisory is limited only to usage with the Silent Knight 5204 and that it does not impact the use of the FW-2 on any other control panels.

If more information is required on this matter, please contact NAPCO Tech Support at 1-800-645-9440.